

Colongra Power Station Monthly Summary Report May 2020

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Comment
LDP1	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	9/06/2020	Normal operation did not exceed 1 hour during the month
LDP1	Nitrogen dioxide - gas	mg/m3	Continuous	42	44	60.0	9/06/2020	
LDP2	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	9/06/2020	Normal operation did not exceed 1 hour during the month
LDP2	Nitrogen dioxide - gas	mg/m3	Continuous	0	0	60.0	9/06/2020	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	9/06/2020	Normal operation did not exceed 1 hour during the month
LDP3	Nitrogen dioxide - gas	mg/m3	Continuous	55	55	60.0	9/06/2020	
LDP4	Nitrogen dioxide - diesel	mg/m3	Continuous	0	0	90.0	9/06/2020	No diesel generation during the month
LDP4	Nitrogen dioxide - gas	mg/m3	Continuous	46	46	60.0	9/06/2020	

Correction Log

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Mean Hourly Average	Max Hourly Average	100 Percentile limit	Published Date	Reason for Correction
--------------------------------	-----------	-----------------	----------------------	---------------------	--------------------	----------------------	----------------	-----------------------

Original Data

Corrected Data