

Colongra Power Station Monthly Summary Report December 2024

Premises Details

Environment Protection Licence No. 13036

Licencee's Name Snowy Hydro Limited

Premises Name Colongra Power Station

Premises Address Off Scenic Drive, Budgewoi NSW 2262

Link to EPA Public Register Click Here

Link to EPL13036 on EPA Public Register Click Here

Summary of Monitoring Data

| Monitoring Location / EPA ID No. | Pollutant | Unit of Measure | Monitoring Frequency | Monitoring Period | Min Hourly Average | Mean Hourly Average | Max Hourly Average | 100 Percentile Concentration Limit | Published Date | Comment |
|--|--------------------------|--------------------|-----------------------------|----------------------|-----------------------|------------------------|-----------------------|--|-------------------|---------------------------------------|
| 1 | Nitrogen Oxides - Gas | mg/m3 | Continuous during discharge | December 2024 | 38.8 | 39.4 | 41.1 | 60 | 13 Jan 2025 | |
| 1 | Nitrogen Oxides - Diesel | mg/m3 | Continuous during discharge | December 2024 | 47.9 | 53.1 | 56.7 | 90 | 13 Jan 2025 | |
| 2 | Nitrogen Oxides - Gas | mg/m3 | Continuous during discharge | December 2024 | 35.2 | 42.6 | 48.4 | 60 | 13 Jan 2025 | |
| 2 | Nitrogen Oxides - Diesel | mg/m3 | Continuous during discharge | December 2024 | 57.4 | 62.1 | 66.7 | 90 | 13 Jan 2025 | |
| 3 | Nitrogen Oxides - Gas | mg/m3 | Continuous during discharge | December 2024 | 26.5 | 31.9 | 45.7 | 60 | 13 Jan 2025 | |
| 3 | Nitrogen Oxides - Diesel | mg/m3 | Continuous during discharge | December 2024 | 63.0 | 63.0 | 63.0 | 90 | 13 Jan 2025 | |
| 4 | Nitrogen Oxides - Gas | mg/m3 | Continuous during discharge | December 2024 | 34.3 | 40.1 | 51.3 | 60 | 13 Jan 2025 | |
| 4 | Nitrogen Oxides - Diesel | mg/m3 | Continuous during discharge | December 2024 | 0.0 | 0.0 | 0.0 | 90 | 13 Jan 2025 | No diesel generation during the month |

Notes on data summary:

- Sampling is undertaken in accordance with the "Approved Methods for the Sampling and Analysis of Air Pollutants in NSW", Method CEM-2
- Sample Type and Location: Discharge to air emissions monitoring from turbine exhaust stacks
- For the purpose of the licence, Nitrogen Oxides means: Nitrogen Dioxide (NO2) or Nitric Oxide (NO) or both, as NO2 equivalent.
- mg/m3 refers to milligrams per metre cubed



Correction Log

| Monitoring Location / EPA ID No. | Pollutant | Unit of Measure | Monitoring Frequency | Monitoring Period | Original Data | Date Originally Published | Corrected Data | Date Corrected | Reason for Correction |
|--|-----------|--------------------|-------------------------|----------------------|---------------|------------------------------|----------------|----------------|-----------------------|
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

Aerial Image and Monitoring Locations

Note: Site boundaries and monitoring locations displayed are indicative only.

